

Moberly Fire Department Inspection Report

Certified Final Occupancy

Business Address		Business Name	
Phone Number		Owner Agent	
Emergency Contact		Emergency Phone	
Owner Email address		Inspectors Name	
<p>An inspection on this date of premises by Moberly Fire Department Shows the existence of the following violation of the 2012 International Fire Code, which was adopted by The City of Moberly, Ordinance 9026. For the safety of the occupants, you must correct each violation by complying with this order. A re-inspection will be scheduled by this department no more then ten business days from the date of this inspection to make sure have complied with fire code.</p>			
Outside			
304.1		Waste accumulation prohibited	Pass
505.1		Address provided and readable from street and alley	Pass
912.3		sprinkler connection in not obstructed or blocked	NA
Means of Egress			
703.2.2		Stairwell and other fire doors shall not be blocked open	Pass
1004.3		Occupant load posted near the main exit (if required)	Pass
1006.1		Means of egress must remain illuminated at all times	Pass
1003.6		Means of egress unobstructed-exit doors must remain unlocked	Pass
Storage and General Warehouse			
304.3.1		Storage of oily rags must in self-closing metal cabinet	Pass
315.3		All storage shall be neat, orderly and away from heat	Pass
315.3.1		Storage more than 18 inches from sprinkler head	Pass
315.3.1		Storage more than 2 feet from ceiling (no sprinkler)	Pass
2704.2.1		Flammable storage cabinet needed	Pass
5303.5.3		Gas containers, cylinders, and tanks properly secured	Pass
Electrical			
605.1		Electrical wiring and/or components need repair	Pass
605.3		At least 30 inches of clean ace from electrical equipment	Pass
605.3.1		Circuits marked for proper usage	Pass
605.4		Eliminate use of multi-plug adapters	Pass
605.5		Proper use of extension	Pass
605.6		Approved covers for junction boxes and cover plates	Pass
Fire Separation			
703.1		Fire wall / separations intact with no breaches	Pass
703.2.2		Proper hold open devices	Pass
703.2.3		Closing device operable	Pass
Fire Extinguishers			
906.6		Fire extinguishers installed in readily accessible and visible location	Pass

906.2		Fire extinguishers inspected monthly, and service annually		Pass
Sprinkler & Fire Alarm Systems				
912.2.2		Approved sign or arrows to indicate location of hidden FDC		NA
912.3		Clear access to FDC without obstructions		NA
912.4		Has metal sign with raised letters at least 1" in size above FDC		NA
912.5		Backflow protection installed		NA
913.5		Inspect and test fire pump	Date of test	NA
901.6.1		Inspect and test standpipes	Date of test	NA
901.4		Fire protection systems maintained	Date of test	NA
901.8.1		No tampering with equipment		NA
Hood and Duct Systems				
901.6.2		Provide record of inspection and testing of kitchen suppression system		NA
904.11		Automatic extinguishing system for commercial cooking systems		NA
609.1		commercial kitchen exhaust hood	Date of test	NA
609.3.2		Hood and duct system is clean (no grease accumulation present)		NA
609.3.1		Six month inspection of kitchen hood and suppression systems		NA
Boiler and Mechanical Room Hazards				
605.3.1		Electrical and mechanical rooms labeled		Pass
603.5.2		Emergency shut-off to heating units must be present		Pass
603.6		Maintain chimney and heating units in a safe conditions		Pass
703.1		Boiler room door must be self-closing, one hour fire-resistant rated		Pass
Emergency Building Services				
1008.1.9		Panic and fire exits hardware in working order (doors swing out)		Pass
5003.4		SDS sheets on file (when required)		Pass
Knox Box location				
Notes and comments				
Inspector's Signature			Owner / Agent Signature	
Inspection Date		Re-Inspection Date		